

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE	PAGE 1	OF PAGES 1
2. AMENDMENT/MODIFICATION NO. 0002		3. EFFECTIVE DATE 2/28/12		4. REQUISITION/PURCHASE REQ. NO. DTFAWN-12-R-00036		5. PROJECT NO. <i>(If applicable)</i>
6. ISSUED BY Federal Aviation Administration Acquisition Management Branch, ANM52 1601 Lind Ave SW Renton WA 98057				7. ADMINISTARTED BY <i>(If other than Item 6)</i>		
8. NAME AND ADDRESS OF CONTRACTOR <i>(No., street, county, State and ZIP Code)</i>				9A. AMENDMENT OF SOLICITATION NO. DTFAWN-12-R-00036 9B. DATED <i>(SEE ITEM 11)</i> February 01, 2012		
CODE				10A. MODIFICATION OF CONTRACT/ORDER NO.		
FACILITY CODE				10B. AWARD DATED <i>(SEE ITEM 13)</i>		
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS						
The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is not extended.						
Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation on as amended, by one of the following methods: (a) By completing Item 8 and 15, and returning <u>1</u> copies of the amendment; (b) acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hours and date specified.						
12. ACCOUNTING AND APPROPRIATION DATA <i>(If required)</i>						
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.						
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: <i>(Specify authority)</i> THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT/ORDER NO. IN ITEM 10A.						
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES <i>(such as changes in paying office, appropriation data, etc.)</i> SET FORTH IN ITEM 14.						
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:						
D. OTHER <i>(Specify type of modification and authority)</i>						
E. IMPORTANT: Contractor is required to sign this document and return <u>1</u> copy to the issuing office.						
14. DESCRIPTION OF AMENDMENT/MODIFICATION <i>(Organized by UCF section headings, including solicitation/contract subject matter where feasible.)</i> The above referenced solicitation for the Mt. Humboldt, Security Equipment Installation and Soils Correction, is amended as follows: The purpose of this modification is address all questions submitted in reference to the RFO and site visit February 16th, 2012 THE DATE SUBMISSIONS ARE DUE HAS CHANGED TO MONDAY MARCH 5th, 2012. ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED. Except as provided herein, all terms and conditions of the referenced document in Item 9A or 10A, remains unchanged and in full force and effect.						
15A. NAME AND TITLE OF SIGNER <i>(Type or print)</i>				16A. NAME AND TITLE OF CONTRACTING OFFICER <i>(Type or print)</i>		
15B. CONTRACTOR/OFFEROR		15C. DATE SIGNED		16C. DATE SIGNED		BY
_____ <i>(Signature of person authorized to sign)</i>				_____ <i>(Signature of Contracting Officer)</i>		

**Amendment 0002
February 28th 2012
RFO No. DTFAWN-12-R-00036**

The referenced solicitation for the Redmond, Security Gate and Installation, is amended as follows:

A. The date for receipt of offers has changed. It is now March 05, 2012 at 4:00pm Pacific Time.

B. The purpose of this modification is notify all prospective bidders that a site visit was held on **Thursday February 16th at 9 AM PST** onsite, all contact and site information was available in the original RFO. **THE FOLLOWING ARE QUESTIONS AND ANSWERS BROUGHT UP.**

C. The following questions were asked:

Is there a maintenance contract for the existing security gate system at the tower?

The answer is yes.

The contract is a national contract with Defense and Space Honeywell Technology Solutions, phone number 410-964-7000. Contract Number is DTFAWA-11-C-00005.

Here are questions and answers from the February 16 site visit to the Redmond ATCT.

1. Spare port on Noistas/Meridian phone system?
Yes. However using a master station in the cab that is compatible with the keypad/intercom station at the gate in lieu of connecting to the phone system is acceptable. If submitted estimate accounts for a switch to master station please submit specifications, or cut sheets.
2. Where to mount camera?
On a 10' pole as shown on drawings RDM-897196-C002 and C003.
3. What breakers and panel can be used?
Use breaker 19 for camera, motion detector and led light and breakers 44 and 46 for the gate operator in panel ELPA as shown on drawing RDM-807196-E001.
4. What is the routing of the 2" and 1/2" conduit that runs from the tower to the stub up?
The exact rout is unknown. The route shown on drawing RDM-807196-C001 is the approximate route.
5. Who is responsible for saw cutting, trenching and backfill?
The prime contractor is responsible for this work. He can do it himself or use a subcontractor.
6. The gate intercom call box (2520-410:Outdoor Intercom Station with Keypad and Gooseneck) specified in the Project Specifications Section 4.2 will not work with the Meridian phone system without costly modifications. Instead of trying to connect the

gate intercom system to the phone system, could it be connected to a separate and new intercom master in the tower? This way the intercom system will operate independent of the phone system, and will not tie up the phone line in the tower while the intercom is in use. The installation cost will also be less.

Yes, a separate intercom master may be used in lieu of connecting to the phone system. A door release for the gate may be included with the master station. Submittals will be required for approval.

NOTE:

All work in the Tower Cab and the exothermic welding in the Electrical Room must be accomplished between the hours of 8pm and 5am so as not to interfere with Air Traffic Control Operations.